

ZONE 0

The interior of the bath or shower tray

ZONE 1

Above the bath or shower tray to a height of 2.25 metres from the floor

ZONE 2

Outside the bath or shower, extending 0.6 metres beyond zone 1 and including the area around wash basins

ZONE 3

Outside zones 0, 1 or 2 and where no water jet is likely to be used for cleaning purposes. No specific IP rating is required.

If water jets are used for cleaning in zones 1, 2 or 3, a fitting must have a minimum IPx5 rating

All electrical work inside a bathroom must be carried out by a qualified electrician - please refer to the latest wiring regulations for your region

